

Macallen Dam Abutments and Outlet Structure Rehabilitation Project
Newmarket, NH
ADDENDUM NO. 3

To: All Prospective Bidders
Macallen Dam Abutments and Outlet Structure Rehabilitation Project

Location: Macallen Dam, Newmarket, NH

From: Todd E. Monson – GZA GeoEnvironmental, Inc.
Chad W. Cox – GZA GeoEnvironmental, Inc.
James P. Guarente – GZA GeoEnvironmental, Inc.

Re: **Addendum No. 3**

Date: April 12, 2019

Please find the following **ADDENDUM NO. 3** for the Macallen Dam Abutments and Outlet Structure Rehabilitation Project which is to be included as part of the Contract Documents thereof.

General Bidders shall acknowledge receipt of this **Addendum No. 3** by checking the appropriate box on Sheet 2 of the Bid Form.

Item #1: Prevailing Wage Clarification

The contract will not require prevailing wage.

Item #2: Allowable Drawdown Period

Via telephone communication on April 12, 2019, New Hampshire Fish and Game Department (NHFG) has indicated a drawdown of the impoundment would be allowed for six weeks between September 1st and October 15th. If the Contractor determines further extension of the drawdown window is necessary, they shall request such modification in writing to the Engineer (copy to the Town). The Engineer will coordinate with NHFG to address the requested modification. It is recommended that any modification request be submitted soon after NTP so as to provide NHFG sufficient advance notice for making their decision and adequate time for the Contractor to adjust their construction sequence/approach based on NHFG's ultimate response. There is no guarantee that an additional drawdown extension beyond 8 weeks will be permitted. As indicated in the February 22, 2019 letter from NHFG, re-filling of the impoundment shall be coordinated with the schedule for the drawdown of the Pawtuckaway Lake in mid-October.